



## Errata

### NFPA 70<sup>®</sup>

### *National Electrical Code*<sup>®</sup>

#### 2017 Edition

**Reference: 840.3(G)**

**Errata No: 70-17-2**

Code-Making Panel 16, and the Correlating Committee on National Electrical Code note the following errors in the 2017 edition of *NFPA 70<sup>®</sup>, National Electrical Code<sup>®</sup>*.

*1. Update a reference in 840.3(G) to read as follows:*

**840.3(G) Electrical Classification of Data Circuits and Cables.** Sections 725.139(D)(1) and 800.133(A)(1)(b) shall apply to the electrical classification of Class 2 and Class 3 circuits in the same cable with communications circuits.

Issue Date: December 16, 2016

**(Note: Electronic products and pamphlet reprints may have this errata incorporated. For current information about the NFPA Codes and Standards, including this errata, please see [www.nfpa.org/docinfo](http://www.nfpa.org/docinfo))**

Copyright © 2016 All Rights Reserved  
NATIONAL FIRE PROTECTION ASSOCIATION