



Tentative Interim Amendment

NFPA 70[®]

National Electrical Code[®]

2017 Edition

Reference: 690.56(C)

TIA 17-1

(SC 16-8-15 / TIA Log #1233)

Note: Text of the TIA was issued and approved for incorporation into the document prior to printing.

1. Revise 690.56(C) to read as follows:

(C) Buildings with Rapid Shutdown. Buildings with PV systems shall have permanent labels as described in 690.56(C)(1) through (C)(3).

Issue Date: August 4, 2016

Effective Date: August 24, 2016

(Note: For further information on NFPA Codes and Standards, please see www.nfpa.org/docinfo)

Copyright © 2016 All Rights Reserved
NATIONAL FIRE PROTECTION ASSOCIATION